




Engineering • Design • Consulting



March 6, 2018

To: Prospective Bidders
Subject: ADDENDUM NO.1 TO THE BIDDING DOCUMENTS FOR:

**PARKING LOT IMPROVEMENTS FOR
WEST MEADOWS ICE ARENA
3939 WINNETKA AVENUE, ROLLING MEADOWS, IL**

W-T Civil Engineering Project No. CE17033

GENERAL CLARIFICATIONS:

1. The note within the plans and Geotechnical Report that pertains to “NON-FROST SUSCEPTIBLE AGGREGATES”, indicates that the IDOT CA-6 or CA-1 aggregate that is used on this project shall not contain any chert.
2. The Owner will hire the materials tester. Contractor will coordinate with material tester for scheduling.

**Regards,
The W-T Group, LLC**

A handwritten signature in black ink, appearing to read 'Esther K. Markwart'.

**Esther K. Markwart, E.I.T.
Project Engineer**